



## (M) FAN MOTOR LOCATION.

MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT	HEAVIEST SECTION (PAN)	A	H
VT1-825-P	24000	45980	15300	12'-2 7/8"	12'-10 5/8"
VT1-921-0	25770	47750	14730	13'-11 7/8"	14'-9 3/8"
VT1-1020-P	26340	48320	15300	13'-11 7/8"	14'-9 3/8"
VT1-1125-P	29250	51230	15300	15'-4 5/8"	16'-2 1/8"
VT1-1200-Q	29370	51350	15420	15'-4 5/8"	16'-2 1/8"
VT1-1245-R	29730	51710	15780	15'-4 5/8"	16'-2 1/8"
VT1-1335-S	29790	51770	15840	15'-4 5/8"	16'-2 1/8"

## NOTES:

1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
2. UNLESS OTHERWISE INDICATED, ALL CONNECTIONS 6 INCHES AND SMALLER ARE MPT AND CONNECTIONS 8 INCHES AND LARGER ARE BEVELED FOR WELDING.
3. SUCTION CONNECTIONS ARE LOCATED ON BOTH ENDS OF TOWER AND BOTH CONNECTIONS MUST BE USED.
4. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.

B.A.C.  
ORDER NO:  
DATE:



BALTIMORE AIRCOIL  
COMPANY

COOLING TOWER  
RH UNIT

DRAWING NUMBER:  
BAC-10006 A