



| Model Number | Approx. Shipping Weight | Approx. Operating Weight |
|-------------------|-------------------------|--------------------------|
| PCC-0538-1024N060 | 25320 | 37230 |
| PCC-0416-1024N020 | 25590 | 37550 |
| PCC-0466-1024N030 | 25840 | 37800 |
| PCC-0544-1024N040 | 29670 | 41790 |
| PCC-0562-1024N050 | 28740 | 40860 |
| PCC-0590-1024N060 | 28840 | 40960 |
| PCC-0630-1024N080 | 30260 | 42440 |
| PCC-0646-1024N060 | 35890 | 48400 |
| PCC-0492-1024N020 | 36920 | 49530 |
| PCC-0656-1024N060 | 37490 | 50110 |

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PCC Evaporative Condenser
Tabulated Steel Support - Plan A**

DRAWING NUMBER:
SS-PCI-1024