



Model Number	Approx. Shipping Weight	Approx. Operating Weight
PCC-0498-1224N020	33670	48750
PCC-0530-1224N030	30960	45870
PCC-0586-1224N030	38130	53450
PCC-0618-1224N040	35680	50860
PCC-0660-1224N050	35740	50920
PCC-0692-1224N050	40330	55780
PCC-0730-1224N060	40430	55880
PCC-0792-1224N080	40810	56250
PCC-0710-1224N050	42520	58210
PCC-0750-1224N060	42620	58310
PCC-0790-1224N080	40660	56200
PCC-0812-1224N080	43000	58680

PLAN VIEW

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

PLAN A STEEL SUPPORT

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PCC Evaporative Condenser  
Tabulated Steel Support - Plan A**

DRAWING NUMBER:  
**SS-PCI-1224**