



### PLAN VIEW

Model Number	Approx. Shipping Weight	Approx. Operating Weight
PCC-1079-1240N080	47856	71650
PCC-0855-1240N030	49660	73590
PCC-0974-1240N040	54780	79020
PCC-1071-1240N080	54940	79180
PCC-1153-1240N080	55380	79620
PCC-1218-1240N100	55430	79670
PCC-1030-1240N040	62916	87780
PCC-1105-1240N050	66916	92030
PCC-1125-1240N060	63076	87940
PCC-1151-1240N060	67016	92130
PCC-1173-1240N080	60236	84890
PCC-1234-1240N080	67456	92570
PCC-1270-1240N100	63566	88430
PCC-1308-1240N100	67506	92620
PCC-1367-1240N120	68008	93120

**Notes**

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:  
DATE:



PCC Evaporative Condenser  
Tabulated Steel Support - Plan A  
DRAWING NUMBER:  
**SS-PPC-1240**