



Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches, weights are in pounds. Refer to submittal drawings for actual dimensions and weights.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

Model Number	Approx, Shipping Weight	Approx, Operating Weight
PFI-0406N-3DXDZ-X1	3210	4690
PFI-0406N-3DXEZ-X1	3670	5230
PFI-0406N-4DXEZ-X1	3810	5400
PFI-0406N-4DXDZ-X1	3670	5310
PFI-0406N-5DXEZ-X1	4110	5810
PFI-0406N-5DXDZ-X1	4470	6350
PFI-0406N-6DXDZ-X1	4540	6420

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PFI Closed Circuit Cooling Tower  
Tabulated Steel Support - Plan A**

DRAWING NUMBER:  
**SS-PFI-0406**