



Model Number	Approx, Shipping Weight	Approx, Operating Weight
PFI-0718N-2DXDS-X2	12890	19460
PFI-0718N-2DXES-X2	14190	20910
PFI-0718N-3DXDS-X2	15370	22850
PFI-0718N-3DXES-X2	14650	21570
PFI-0718N-4DXDS-X2	17290	25550
PFI-0718N-4DXES-X2	17890	26180
PFI-0718N-5DXES-X2	18330	26760
PFI-0718N-6DXDS-X2	18350	27030
PFI-0718N-6DXES-X2	20440	29530

- Notes
- 1) Drawings are not to scale. All dimensions are in feet and inches, weights are in pounds. Refer to submittal drawings for actual dimensions and weights.
 - 2) Operating weight and weight loading are for units with water level in basin at overflow.
 - 3) Unit support beams and anchor bolts to be designed and furnished by others.
 - 4) Support beams must be flush and level at top.
 - 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
 - 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:
DATE:



**PFI Closed Circuit Cooling Tower
Tabulated Steel Support - Plan A**
DRAWING NUMBER:
SS-PFI-0718