



Model Number	Approx, Shipping Weight	Approx, Operating Weight
PFI-1218N-2DXDS-X1	20450	31110
PFI-1218N-2DXES-X1	21300	32010
PFI-1218N-3DXDS-X1	23550	35570
PFI-1218N-3DXES-X1	24930	36990
PFI-1218N-4DXDS-X1	26930	40300
PFI-1218N-4DXES-X1	28360	41780
PFI-1218N-5DXES-X1	28620	42210
PFI-1218N-6DXES-X1	33230	48580

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches, weights are in pounds. Refer to submittal drawings for actual dimensions and weights.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PFI Closed Circuit Cooling Tower
Tabulated Steel Support - Plan A**

DRAWING NUMBER:
SS-PFI-1218