



Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PCC-0498-1224N020	33670	48750	13930	4'-8 1/8"	17'-8 1/4"
PCC-0530-1224N030	30960	45870	12570	4'-0 5/8"	17'-0 3/4"
PCC-0586-1224N030	38130	53450	16150	5'-3 5/8"	18'-3 3/4"
PCC-0618-1224N040	35680	50860	14930	4'-8 1/8"	17'-8 1/4"
PCC-0660-1224N050	35740	50920	14960	4'-8 1/8"	17'-8 1/4"
PCC-0692-1224N050	40330	55780	17250	5'-3 5/8"	18'-3 3/4"
PCC-0730-1224N060	40430	55880	17300	5'-3 5/8"	18'-3 3/4"
PCC-0792-1224N080	40810	56250	17490	5'-3 5/8"	18'-3 3/4"
PCC-0710-1224N050	42520	58210	18350	4'-0 5/8"	17'-0 3/4"
PCC-0750-1224N060	42620	58310	18400	4'-0 5/8"	17'-0 3/4"
PCC-0790-1224N080	40660	56200	17420	4'-0 5/8"	17'-0 3/4"
PCC-0812-1224N080	43000	58680	18590	4'-0 5/8"	17'-0 3/4"

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches.
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the P-Series Counterflow Induced Draft Coil Products rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 8) M = Motor location

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PCC Evaporative Condenser  
Tabulated Unit Print**

DRAWING NUMBER:  
**UP-PCC-1224**