



Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PFI-1024N-2DXDS-X2	21260	32350	8690	4'-0 5/8"	16'-5 5/8"
PFI-1024N-2DXES-X2	24130	35800	10120	4'-8 1/8"	17'-1 1/8"
PFI-1024N-3DXDS-X2	24440	36730	10280	4'-0 5/8"	16'-5 5/8"
PFI-1024N-3DXES-X2	26070	38420	11090	5'-3 5/8"	17'-8 5/8"
PFI-1024N-3DXDS-X2	26300	39360	11210	4'-0 5/8"	16'-5 5/8"
PFI-1024N-3DXES-X2	28010	41140	12060	5'-3 5/8"	17'-8 5/8"
PFI-1024N-4DXDS-X2	26550	39580	11330	4'-8 1/8"	17'-1 1/8"
PFI-1024N-4DXES-X2	31790	46380	13950	5'-11 1/8"	18'-4 1/8"
PFI-1024N-5DXDS-X2	30890	45590	13500	5'-3 5/8"	17'-8 5/8"
PFI-1024N-6DXES-X2	33960	49240	15030	7'-1 1/8"	19'-6 1/8"

- Notes
- 1) Drawings are not to scale. Refer to submittal drawings for actual dimensions and weights. All dimensions are in feet and inches, Weights are in pounds.
 - 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
 - 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
 - 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
 - 5) Heaviest section is the combined weight of fan and coil sections, refer to the rigging and assembly manual for suggested lifting method.
 - 6) The area above the discharge must be unobstructed.
 - 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
 - 8) M = Motor location.

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

FACE C

PFI Closed Circuit Cooling Tower Tabulated Unit Print

DRAWING NUMBER:
UP-PFI-1024