



Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PFI-2012N-2DXDS-X2	21260	32350	8690	4'-0 5/8"	16'-5 5/8"
PFI-2012N-2DXES-X2	24130	35800	10120	4'-8 1/8"	17'-1 1/8"
PFI-2012N-3DXDS-X2	26300	39360	11210	4'-0 5/8"	16'-5 5/8"
PFI-2012N-3DXES-X2	28010	41140	12060	5'-3 5/8"	17'-8 5/8"
PFI-2012N-4DXDS-X2	26550	39580	11330	4'-8 1/8"	17'-1 1/8"
PFI-2012N-4DXES-X2	31790	46380	13950	5'-11 1/8"	18'-4 1/8"
PFI-2012N-5DXDS-X2	30890	45590	13500	5'-3 5/8"	17'-8 5/8"
PFI-2012N-6DXES-X2	33960	49240	15030	7'-1 1/8"	19'-6 1/8"

Notes

- 1) Drawings are not to scale. Refer to submittal drawings for actual dimensions and weights. All dimensions are in feet and inches, Weights are in pounds.
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 8) M = Motor location.

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PFI Closed Circuit Cooling Tower Tabulated Unit Print**

DRAWING NUMBER:  
**UP-PFI-2012**