



PLAN VIEW

MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT
VCA-920A	35710	54110
VCA-1086A	35970	54370
VCA-1020A	40700	59370
VCA-1120A	40890	59560
VCA-1200A	40960	59630
VCA-1062A	45690	64630
VCA-1169A	45880	64820
VCA-1240A	45950	64890
VCA-1218A	48900	68030
VCA-1306A	48970	68100
VCA-1414A	54460	73880
VCA-1558A	54880	74300

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

ORDER NO: _____

DATE: _____



Baltimore Aircoil

VCA Unit Support
10'x36'

DRAWING NUMBER: _____