



PLAN VIEW

MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT
VCA-930A	40190	63590
VCA-1052A	40210	63610
VCA-1162A	40250	63650
VCA-1246A	40270	63670
VCA-1248A	46220	69940
VCA-1376A	46240	69960
VCA-1204A	52150	76190
VCA-1327A	52190	76230
VCA-1422A	52210	76250
VCA-1570A	52290	76330
VCA-1501A	56000	80270
VCA-1654A	56080	80350
VCA-1774A	56330	80600
VCA-1790A	62490	87120
VCA-1914A	62740	87370
VCA-2019A	62870	87500

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

ORDER NO: _____

DATE: _____



Baltimore Aircoil

VCA Unit Support
12'x36'

DRAWING NUMBER: _____