



MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT
VCA-122A	6390	9490
VCA-138A	6400	9500
VCA-150A	6430	9530
VCA-161A	6440	9540
VCA-154A	7270	10420
VCA-170A	7300	10450
VCA-182A	7310	10460
VCA-178A	8170	11360
VCA-191A	8180	11370

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator drawings for this data.
- 7) Do not use this drawing to size point vibration isolators. See your BAC Representative for details.

ORDER NO: \_\_\_\_\_

DATE: \_\_\_\_\_



Baltimore Aircoil

VCA Unit Support  
5'x12'

DRAWING NUMBER: \_\_\_\_\_