



MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT
VCA-174A	8170	11960
VCA-192A	8200	11990
VCA-206A	8210	12000
VCA-227A	8280	12070
VCA-195A	9310	13160
VCA-215A	9340	13190
VCA-235A	9350	13200
VCA-259A	9420	13270

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

ORDER NO: \_\_\_\_\_

DATE: \_\_\_\_\_



**Baltimore Aircoil**

VCA Unit Support  
6'x12'

DRAWING NUMBER: \_\_\_\_\_