



MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT
VCA-323A	14990	21710
VCA-356A	15070	21790
VCA-382A	15090	21810
VCA-396A	17070	23900
VCA-424A	17090	23920
VCA-416A	19070	26000
VCA-446A	19090	26020

**Notes**

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

ORDER NO: \_\_\_\_\_

DATE: \_\_\_\_\_



**Baltimore Aircoil**

VCA Unit Support  
8'x18'

DRAWING NUMBER: \_\_\_\_\_