DATAVERSION
DWG Version 2.00

ISOMETRIC DETAIL VIEW

PRESSURE VALVE
MAKE-UP VALVE

3/4" GHT DISCRETE SPRAY
(GARDEN HOSE THREAD)

3/4" MPT MAKE-UP

4'-10 1/8"
2'-11 5/8"

LIFTING POINT TYP

(2) 2 1/8" REFRIG. IN

(2) 2 1/8" REFRIG. OUT

INSPECTION HATCH TYP

8'-2"
7'-0"
6'-8 3/8"
6'-0 1/2"
8 7/8"

1'-2 1/2"
2'-8 3/4"
1'-2 1/2"
2'-8 3/4"
7'-9 3/4"

14'-0 1/2"

6 3/4"
(4) LIFTING POINTS

TERMINAL BOX

2'-0 1/2"
11"
11'-9 5/8"
2 3/8"

6'-10 3/8"

Notes
1) All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
2) Dimensions showing locations of coil & basin connections are approximate and should not be used for prefabrication of connecting piping.
3) For weight loadings and support requirements, refer to the suggested steel support drawing.
4) The area above the fan discharge must not be obstructed.
5) Field piping must not be supported by the unit inlet or outlet connections.

MOTORIZED DRAIN BALL VALVE
1 1/2" FPT DRAIN
2 3/8"
4 1/2"

1 1/2" MPT OVERFLOW
3 1/8"
9 1/4"
11 5/8"

EASY PAD REMOVAL SYSTEM

Model Number	Shipping Weight	Operating Weight	Heaviest Section
TSDC2-CO2-297-18.6	6028	6710	6028

ORDER NO:

DATE:

BAC
BALTIMORE AIRCOIL COMPANY

TrilliumSeries™ Adiabatic Condenser
Six Fan Unit Print

DRAWING NUMBER: