



NOTE:

1. ALL LOCATION DIMENSIONS FOR COIL CONNECTIONS ARE APPROXIMATE AND SHOULD NOT BE USED FOR PREFABRICATION OF CONNECTING PIPING
2. FOR WEIGHT LOADING AND SUGGESTED STEEL SUPPORT REFER TO DRAWING BAC-15036B FOR STANDARD STEEL ARRANGEMENT OR DRAWING BAC-15092B FOR UNITS BEING PROVIDED WITH VIBRATION RAILS.

RIGHT HAND UNIT WITH SIDE OUT PUMP SUCTION

MODEL NO.	APPROX. SHIPPING WEIGHT (LBS)	APPROX. OPERATING WEIGHT (LBS)	F	H
VCL134-K	6160	8590	3'-6 1/2"	7'-8 9/16"
VCL148-L	6220	8650	3'-6 1/2"	7'-8 9/16"
VCL155-L	6950	9450	4'-3 3/4"	8'-4 3/4"

B.A.C. ORDER NO.	BALTIMORE AIRCOIL	EVAPORATIVE CONDENSER	
DATE		DWG NO. BAC-15027B	A