



NOTES:

1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
2. UNLESS OTHERWISE INDICATED ALL CONNECTIONS 3 INCHES AND SMALLER ARE MPT AND CONNECTIONS 4 INCHES AND LARGER ARE BEVELLED FOR WELDING AND GROOVED FOR VICTAULIC CONNECTION.
3. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.
4. PRE-FABRICATION OF FINAL CONNECTING PIPEWORK IS NOT RECOMMENDED.
5. DO NOT SUPPORT PIPING FROM COOLING TOWER. ALL NECESSARY PIPE SUPPORTS ARE TO BE SUPPLIED BY OTHERS.
6. SIZE OVER HEAD PIPING CORRECTLY & KEEP HORIZONTAL OVER HEAD PIPING TO A MINIMUM.

* CASING IS HEAVIEST SECTION

MODEL NO.	APPROX. SHPG. WEIGHT	APPROX. OPER. WEIGHT	HEAV. SECT. (PAN)	A	H
VTO-102-L	2500	3310	1330	8'-1 7/8"	9'-0 1/8"
VTO-107-L	2870	3680	1540 *	9'-7 7/8"	10'-6 1/8"
VTO-116-M	2930	3740	1540 *	9'-7 7/8"	10'-6 1/8"

B.A.C.
ORDER NO:

DATE: / /



BALTIMORE AIRCOIL
COMPANY

COOLING TOWER
DRAWING NUMBER:
BAC-9106 A

C