



NOTE:

1. FOR WEIGHT LOADING AND SUGGESTED STEEL SUPPORT REFER TO DRAWING BAC15036B FOR STANDARD STEEL ARRANGEMENT OR DRAWING BAC-15091B FOR UNITS BEING PROVIDED WITH VIBRATION RAILS.

MODEL NO.	APPROX. SHIPPING WEIGHT (LBS)	APPROX. OPERATING WEIGHT (LBS)	A	H
VTLO82-K	2260	3810	5'-7"	6'-6 1/4"
VTLO92-L	2390	3940	5'-7"	6'-6 1/4"
VTLO95-K	2510	4070	7'-1 5/16"	8'-1 11/16"

REV.B-12/98

B.A.C. ORDER NO.	BALTIMORE AIRCOIL	COOLING TOWER	
DATE		DWG NO. BAC-15002B	B