



NOTE:

1. FOR WEIGHT LOADING AND SUGGESTED STEEL SUPPORT REFER TO DRAWING BAC15036B FOR STANDARD STEEL ARRANGEMENT OR DRAWING BAC-15093B FOR UNITS BEING PROVIDED WITH VIBRATION RAILS.

MODEL NO.	APPROX. SHIPPING WEIGHT (LBS)	APPROX. OPERATING WEIGHT (LBS)	A	H
VTL152-M	3440	6580	4'-1 3/4"	5'-1 1/4"
VTL171-L	3680	6820	5'-8"	6'-6 1/4"
VTL185-M	3820	6960	5'-8"	6'-6 1/4"
VTL198-N	3860	7000	5'-8"	6'-6 1/4"
VTL209-O	3900	7040	5'-8"	6'-6 1/4"
VTL227-O	4330	7470	7'-2 5/16"	8'-1 13/16"

B.A.C. ORDER NO.	BALTIMORE AIRCOIL	COOLING TOWER	
DATE		DWG NO. BAC-15004B	A