

Layout Guidelines

Included are the design layout guidelines for evaporative cooling products in several situations typically encountered by designers. These guidelines represent minimum spacing requirements. If available, greater spacing should be utilized whenever possible.

Overview

Operational efficiency of evaporative cooling equipment depends upon an adequate supply of fresh, ambient air to provide design capacity. Other important considerations, such as the proximity to building air intakes or discharges, also must be taken into account when selecting and designing the equipment site.

As the size of an installation increases, the total amount of heat being rejected into the atmosphere and the volume of discharge air increases — to the point where the units can virtually create their own environment. As a result, it becomes increasingly difficult to apply a set of general guidelines to each case. In such installations, particularly those in wells or enclosures, some air will recirculate. The recirculation should be minimized or design wet-bulb temperature must be adjusted to allow for the recirculation. Consequently, any job that involves four or more cells should be referred to your local BAC Representative for review.

Axial fan units are not generally suited for indoor or ducted applications. In such situations, a centrifugal fan Series V or the Nexus® Modular Hybrid Cooler is recommended.

This section covers the general layout guidelines for the following BAC products:

1. Series 3000 Cooling Towers
2. Series 1500 Cooling Towers
3. FXT Cooling Towers
4. Series V Cooling Towers, Closed Circuit Cooling Towers, and Evaporative Condensers
5. Vertex® Evaporative Condensers
6. CXVB and CXVT Evaporative Condensers
7. FXV and FXV3 Closed Circuit Cooling Towers
8. HXV Hybrid Coolers
9. Nexus® Modular Hybrid Coolers
10. TrilliumSeries® Adiabatic Coolers
11. TrilliumSeries® Dry Coolers



DID YOU KNOW?

As the size of an installation increases, the total amount of heat being rejected into the atmosphere and the volume of discharge air increases — to the point where the units can virtually create their own environment.

For PT2, PFI and PCC layout guidelines, see the separate layout guideline document on page J96. For TrilliumSeries™ Adiabatic Condensers, refer to the Rigging, Installation, Operation & Maintenance Manual at www.baltimoreaircoil.com.

General Considerations

When selecting the site consider the following factors:

1. Locate the unit to prevent the warm discharge air from being introduced into the fresh air intakes of the building(s) served by the unit, intakes of neighboring buildings, or from being carried over any populated area such as a building entrance.
2. Consider the potential for plume formation and its effect on the surroundings, such as large windowed areas, and pedestrian or vehicular traffic arteries, particularly if the unit(s) will be operated during low ambient temperatures.
3. Provide sufficient unobstructed space around the unit(s) to ensure an adequate supply of fresh, ambient air to the air intakes. Avoid situations which promote recirculation of unit discharge air, such as units located:
 - a. Adjacent to walls or structures that might deflect some of the discharge airstream back into the air intakes.
 - b. Where building air intakes or exhausts, such as boiler stacks in the vicinity of the unit, might raise the entering wet bulb temperature or starve the unit of air.
4. Provide adequate space around the unit for piping and proper servicing and maintenance, as shown in **Figures 1**. The fan discharge cylinder must be at least level with or higher than any adjacent walls or buildings.
5. If applicable the top of the fan discharge cylinder, velocity recovery stack, or discharge sound attenuation must be at least level with, and preferably higher than, any adjacent walls or buildings.
6. Orient the unit so the prevailing summer wind blows the discharge air away from the air intakes of the unit(s).
7. When the unit is installed with intake sound attenuation, the distances given in the **Tables 1-15** on pages **J78-J82** should be measured from the face of the intake sound attenuation.
8. On larger unit installations, the problem of ensuring an adequate supply of fresh, ambient air to the tower intakes becomes increasingly difficult. See the “Multi-Cell Installation” section on **page J92**.
9. If the installation does not meet the recommended guidelines, the units will have a greater tendency to recirculate, and the design conditions should be altered to include an allowance for the recirculation. For instance, if the design conditions are 95°F/85°F/78°F (36.7°C/29.4°C/25.6°C) and it was estimated that the allowance for recirculation rate was 1 degree Fahrenheit wet-bulb increase (.56 degrees Celsius), then the new design conditions would be 95°F/85°F/79°F (36.7°C/29.4°C/26.1°C), and the units should be re-selected based on the new design conditions.




Figure 1a. Plan View of the Recommended Unit Servicing and Maintenance Spacing for a Dual Air Intake Unit: Series 3000 Cooling Towers, FXV3 Closed Circuit Cooling Towers, and CXVT Evaporative Condensers (Series 3000 Cooling Tower Shown)




Figure 1b. Plan View of Recommended Unit Servicing and Maintenance Spacing for Single Air Intake Units: Series 1500 Cooling Towers, FXV Closed Circuit Cooling Towers, CXV Evaporative Condensers, and Series V Cooling Towers^[1], Closed Circuit Cooling Towers, and Evaporative Condensers (Series 1500 Cooling Tower Shown)

NOTE:

1. On Models VT0-12 through 176, VC1-10 through 205, VF1-009, 018, 027, 036, and VF1-048 clearance equal to the length of the unit should be provided on one end to facilitate fan shaft removal.




Figure 1c. Plan View of Recommended Unit Servicing and Maintenance Spacing for FXT Cooling Towers

The “Layout Guidelines” describe several typical site layouts for BAC’s cooling products. If these guidelines do not cover a particular situation or if the layout criteria cannot be met, please refer the application to your BAC Representative for review. Please indicate prevailing wind direction, geographic orientation of the unit(s), and other factors such as large buildings and other obstructions that may influence layout decisions.

Installations Adjacent to a Building or Wall(s)

1. Unit Orientation: When a unit is located near a building wall, the preferred arrangement is to have the unit situated with the cased end or blank-off side (unlouvered side) facing the adjacent wall or building. On S15E, CXVB, and FXV models, the motor may be removed from the blank-off side if optional davit arms are provided. Additional clearance would be required to allow access.
2. Air Intake Requirements: Should it be necessary to install a unit with the air intake facing a wall, provide at least distance “d” between the air intake and the wall, as illustrated in Figures 2a and 2b.




Figure 2a. Plan View of a Dual Air Intake Unit Adjacent to Wall




Figure 2b. Elevation View of a Dual Air Intake Unit Adjacent to Wall

Below is the method for determining the minimum acceptable dimension "d" for a unit located with the air intake facing a solid wall:

The maximum acceptable envelope air velocity is 300 FPM^[3], as illustrated in the following equation:

$$\text{Envelope Velocity} = \text{Airflow} / \text{Envelope Area} < 300 \text{ FPM}$$

The envelope area as illustrated on **Figures 2a and 2b** is $[(L+2+2) * d] + [2(H+h) * d]$, where:

"H" – Height of the air intake face in feet

"h" – Elevation of the unit from the roof/ground/pad in feet.

The maximum "h" value is 4'. For units installed at height greater than 4' use $h = 4$.

"L" – Length of the air intake in feet

"d" – Minimum acceptable distance between the wall and the air intake face in feet

"x" – Minimum acceptable distance between wall and discharge face in feet (FXT only)^[2]

$$\text{Therefore, } d = \frac{\text{Airflow}^{[1]}}{300 [L + 4+2 (H+h)]}$$

The minimum acceptable dimension "d" for the products is tabulated in **Tables 1-15 on pages J78-J82**. The distance "d" was calculated using the largest horsepower model in the box size.



NOTES:

1. The louver face airflow for the FXV Closed Circuit Cooling Towers and CXVB Evaporative Condensers is 70% of the total unit airflow. The remaining 30% of the airflow enter the unit through the top of the coil section. Airflow value for crossflow dual air intake units should be 50% of total unit airflow. For FXV3 models, use 35% of total unit airflow.
2. Calculate "x" with same equation for "d" using discharge face dimensions.
3. If a Series V unit cannot be designed to meet these criteria, a tapered discharge hood can be used to increase the maximum allowable downward air velocity to 400 FPM.

Example: Model S3E-1424-12S Adjacent to a Solid Wall

What is the minimum distance required between the air intake of the S3E-1424-12S when installed facing a wall?

Unit Airflow = 262,850 CFM * 3 cells = 788,550 CFM

Note: Series 3000 units are dual air intake units, therefore the air intake airflow is half of the total unit airflow.

$$\text{Airflow} = \frac{\text{Unit Airflow}}{2} = \frac{788,550}{2}$$

Airflow = 394,275 CFM

$H = 19' 9" = 19.75'$, $h = 0'$

$L = 42' 3" = 42.25'$

Solving for "d",

$$d = \frac{\text{Airflow}}{300 [L+4+2(H+h)]}$$

$$d = \frac{394,275}{300 [42.25 + 4 + 2 (19.75 + 0)]}$$

$$d = 15.33'$$

This is rounded to the next 0.5' increment. Therefore, the air intake should be located no less than 15.5' from the solid wall.

Example: Model VT1-415-R Adjacent to a Solid Wall

VT1-415-R with tapered discharge hood is installed adjacent to a solid wall. What is the minimum distance required between the air intake of the **VT1-415-R** when installed facing a wall?

Unit Airflow = 90,250 CFM

$H = 8' 4" = 8.33'$

$h = 0'$

$L = 11' 8" = 11.67'$

Note: With a tapered discharge hood, envelope velocity is increased to 400 FPM.

Solving for "d",

$$d = \frac{\text{Airflow}}{400 [L+4+2(H+h)]}$$

$$d = \frac{90,250 \text{ CFM}}{400 \text{ FPM} [11.67 + 4 + 2(8.33 + 0)]}$$

$$d = 6.98'$$

This is rounded to the next 0.5' increment. Therefore, the air intake should be located no less than 7.0' from the solid wall.

Minimum Acceptable Air Intake Distance "d" (ft) to Solid Wall

Table 1. Series 3000 Cooling Towers

Model Number	One Cell			Two Cell			Three Cell			Four Cell		
	$h=0'$	$h=2'$	$h=4'$	$h=0'$	$h=2'$	$h=4'$	$h=0'$	$h=2'$	$h=4'$	$h=0'$	$h=2'$	$h=4'$
S3E/XES3E-8518-05x	5.0	4.5	4.0	7.5	7.0	6.5	9.5	8.5	8.0	10.5	10.0	9.0
S3E/XES3E-8518-06x	5.5	5.0	4.5	8.5	8.0	7.5	11.0	10.0	9.5	12.0	11.5	11.0
S3E/XES3E-8518-07x	6.0	5.5	5.0	9.5	9.0	8.0	12.0	11.0	10.5	13.5	13.0	12.0
S3E/XES3E-1020-06x	5.5	5.0	4.5	8.5	8.0	7.5	10.5	10.0	9.5	12.0	11.5	10.5
S3E/XES3E-1020-07x	6.0	5.5	5.0	9.5	9.0	8.5	12.0	11.0	10.5	13.5	12.5	12.0
S3E/XES3E-1222-06x	6.0	5.5	5.0	9.0	8.5	8.0	11.0	10.5	9.5	12.0	11.5	11.0
S3E/XES3E-1222-07x	7.5	7.0	6.5	11.5	10.5	10.0	14.0	13.0	12.5	15.5	14.5	14.0
S3E/XES3E-1222-10x	8.0	7.5	7.0	12.5	12.0	11.0	15.5	15.0	14.0	18.0	17.0	16.5
S3E/XES3E-1222-12x	7.5	7.0	6.5	12.0	11.5	11.0	15.5	14.5	14.0	17.5	17.0	16.5
S3E/XES3E-1222-13x	7.5	7.0	6.5	12.0	11.5	11.0	15.5	14.5	14.0	17.5	17.0	16.5
S3E/XES3E-1222-14x	8.0	7.5	7.0	13.0	12.5	11.5	16.5	16.0	15.0	19.5	18.5	18.0
S3E/XES3E-1424-07x	8.0	7.5	7.0	12.0	11.0	10.5	14.0	13.5	12.5	15.5	15.0	14.5
S3E/XES3E-1424-12x	9.0	8.0	7.5	14.0	13.0	12.5	17.5	16.5	16.0	19.5	19.0	18.0
S3E/XES3E-1424-13x	8.5	8.0	7.5	14.0	13.0	12.5	17.0	16.5	16.0	19.5	19.0	18.0
S3E/XES3E-1424-14x	8.5	8.0	7.5	14.0	13.0	12.5	17.5	16.5	16.0	20.0	19.0	18.5



NOTES:

Refer to notes on page J77 for calculation information.

Table 2. Series 1500 Cooling Towers

Model Number	One Cell			Two Cell			Three Cell			Four Cell		
	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
S15E/XE15E-1285-06x	5.5	5	4.5	8.5	8	7	10.5	9.5	9	11.5	11	10.5
S15E/XE15E-1285-07x	6	5.5	5	9	8.5	8	11.5	10.5	10	13	12	11.5
S15E/XE15E-1285-09x	6	5	5	9.5	8.5	8	11.5	11	10	13.5	12.5	12
S15E/XE15E-1285-10x	6	5.5	5	9.5	9	8.5	12.5	11.5	11	14.5	13.5	13
S15E/XE15E-1212-07x	7.5	7	6	11	10	9.5	13	12.5	11.5	14.5	14	13
S15E/XE15E-1212-09x	7.5	7	6.5	11.5	11	10	14.5	13.5	13	16	15.5	14.5
S15E/XE15E-1212-10x	8	7.5	7	12.5	12	11	15.5	14.5	14	17.5	17	16
S15E/XE15E-1212-11x	8	7.5	7	12.5	11.5	11	15.5	14.5	14	17.5	17	16
S15E/XE15E-1212-12x	8	7	6.5	12.5	11.5	11	15.5	14.5	14	17.5	17	16
S15E/XE15E-1218-07x	9.5	8.5	8	13	12	11.5	15	14.5	13.5	16.5	15.5	15
S15E/XE15E-1218-09x	9.5	9	8.5	14	13.5	12.5	16.5	16	15	18	17.5	17
S15E/XE15E-1218-10x	10.5	9.5	9	15.5	14.5	14	18	17.5	16.5	20	19.5	18.5
S15E/XE15E-1218-11x	10.5	9.5	9	15.5	14.5	14	18.5	17.5	17	20.5	19.5	19
S15E/XE15E-1218-12x	10	9.5	9	15	14.5	13.5	18.5	17.5	17	20.5	19.5	19

Table 3. VTO and VT1 Cooling Towers

Model Number	No Discharge Hood			4' Discharge Hood		
	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
VT0-12-E to VT0-176-0	5	6	3	3.5	3	3
VT1-N209-P to VT1-N255-P	6.5	6	5	5	4.5	4
VT1-N301-Q to VT1-N395-R	8	7.5	6.5	6	5.5	5
VT1-N418-P to VT1-N510-P	9	8.5	7.5	7	6.5	6
VT1-M316-0 to VT1-M420-R	8.5	7.5	6.5	6.5	5.5	5
VT1-M431-0 to VT1-M610-R	10.5	9.5	8.5	8	7	6.5
VT1-M632-0 to VT1-M840-R	12	11	10	9	8.5	7.5
VT1-M948-0 to VT1-M1260-R	14	13.5	12.5	11	10	9.5
VT1-275-P to VT1-415-R	9	8.5	7.5	7	6.5	6
VT1-416-0 to VT1-600-P	11.5	10.5	9	8.5	8	7
VT1-550-P to VT1-830-R	13.5	12.5	11.5	10	9.5	8.5
VT1-825-P to VT1-1335-S	17	16	15	13	12	11.5

Table 4. VTL Cooling Towers

Model Number	No Discharge Hood			4' Discharge Hood		
	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
VTL-016-E to VTL-039-H	3	3	3	3	3	3
VTL-045-H to VTL-079-K	3	3	3	3	3	3
VTL-082-K to VTL-095-K	3	3	3	3	3	3
VTL-103-K to VTL-137-M	4.5	3.5	3	3	3	3
VTL-152-M to VTL-227-O	6	5	4.5	4.5	4	3
VTL-245-P to VTL-272-P	7	6	5.5	5	4.5	4

Minimum Acceptable Air Intake Distance "d" (ft) to Solid Wall

Table 5. FXV Closed Circuit Cooling Towers and HXV Hybrid Coolers

Model Number	One Cell						
	h=0'	h=2'	h=4'	Model Number	h=0'	h=2'	h=4'
FXV-0806A, 0806B	4	3.5	3	FXV-0818B	8	7.5	7
FXV-0809A	5	4	3.5	FXV-1212B, HXV-1212N-1B	7.5	6.5	6
FXV-0809B	5	4.5	4	FXV-1212C, HXV-1212N-1C	8	7	6.5
FXV-0812A	6	5	4.5	FXV-1218B, HXV-1218N-1B	9.5	8.5	8
FXV-0812B	6.5	5.5	5	FXV-1218C, HXV-1218N-1C	10	9	8.5
FXV-0818A	7	6.5	6				

Table 6. TrilliumSeries® Adiabatic Cooler

Model Number	h=0'	h=2'	h=4'
TRF-1010N-Cxxxx17E	3	2.5	2.0
TRF-1014N-Cxxxx26E	3.5	3.5	3
TRF-1018N-Cxxxx34E	4.5	4	4
TRF-1022N-Cxxxx43E	5	4.5	4.5
TRF-1026N-Cxxxx51E	5.5	5	5
TRF-1030N-Cxxxx60E	6	5.5	5.5
TRF-1034N-Cxxxx68E	6.5	6	5.5
TRF-1038N-Cxxxx77E	7.0	6.5	6.0

Table 8. FXT Cooling Towers

Model Number	h=0'		h=2'		h=4'	
	x	d	x	d	x	d
FXT-0506A-X	3	3	3	3	3	3
FXT-0706B-X	4	4	3.5	3.5	3	3
FXT-0709B-X	5	5	4.5	4.5	4	4
FXT-0712B-X	6.5	6.5	5.5	5.5	5	5
FXT-0712C-X	6.5	6.5	6	6	5.5	5.5

Table 7. TrilliumSeries® Dry Cooler

Model Number	h=0'	h=2'	h=4'
TDFS1238N-C80EQ20B	10.5	10	9.5
TDFS1238N-C80EQ25B	11	10.5	10
TDFS1238N-C80EQ30B	12	11.5	11
TDFS1238N-C80EQ35B	12.5	12	11.5
TDFS1238N-C80EQ40B	13	12.5	12
TDFS1238N-C60ET20B	10	9.5	9.0
TDFS1238N-C60ET25B	10.5	10	9.5
TDFS1238N-C60ET30B	11.5	11	10.5
TDFS1238N-C60ET35B	12	11.5	11
TDFS1238N-C60ET40B	12.5	12	11.5

Table 9. CXVB Evaporative Condensers

Model Number	One Cell			Two Cell		
	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
CXVB-X-0806-X	4	3.5	3	—	—	—
CXVB-X-0809-X	5	4.5	4	—	—	—
CXVB-X-0812-X	6	5.5	5	—	—	—
CXVB-X-0818-X	8	7	6.5	—	—	—
CXVB-X-1212-X	7.5	7	6.5	11.5	10.5	10
CXVB-X-1218-X	9.5	9	8.5	13.5	13	12

Table 10. FXV3 and CXVT Units

FXV3 Model Number	CXVT Model Number	One Cell			Two Cell		
		h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
FXV3-1224-X-X	CXVT-x-1224-x and XECXVTx-1224-x	6	5.5	5	9.5	9	8.5
FXV3-1426-X-X	CXVT-x-1426-x and XECXVTx-1426-x	7	6.5	6	11	10.5	10
—	CXVT-x-2424-x and XECXVTx-2424-x	—	—	—	9.5	9	8.5
—	CXVT-x-2826-x and XECXVTx-2826-x	—	—	—	11	10.5	10

Table 11. VF1 and VC1 Units

Model Number		No Discharge Hood			4' Discharge Hood		
		h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
VF1-009-XXX	VC1-10 to 25	3	3	3	3	3	3
VF1-018-XXX	VC1-30 to 65	3	3	3	3	3	3
VF1-027-XXX	VC1-72 to 90	3	3	3	3	3	3
VF1-036-XXX	VC1-100 to 135	4	3.5	3	3	3	3
VF1-048-XXX	VC1-150 to 205	5	4.5	4	3.5	3	3
VF1-072-XXX	VC1-N208 to N230	6.5	5.5	5	5	4	3.5
VF1-096-XXX	VC1-N243 to N315	7	6	5.5	5	4.5	4
VF1-144N-XXX	VC1-N338 to N470	7	6.5	6	5	4.5	4
VF1-192-XXX	—	10	9	8	7	6.5	6
VF1-288N-XXX	—	9.5	8.5	8	7	6.5	6
VF1-1012N-XXXXX-XX	—	6.5	6	5.5	5.5	5	5
VF1-1018N-XXXXX-XX	—	9	8	7.5	7.5	7	6.5
VF1-1024N-XXXXX-XX	—	10	9.5	9	9	8.5	8
VF1-1036N-XXXXX-XX	—	13	12	11.5	11.5	11	10.5
VF1-144-XXX	VC1-386 to 516	10	9	8	7.5	6.5	6
VF1-216-XXX	VC1-540 to 804	13	11.5	10.5	9.5	8.5	8
VF1-288-XXX	VC1-772 to 1032	13.5	12.5	11.5	10	9.5	8.5
VF1-432-XXX	VC1-1158 to 1608	17.5	16	15	13	12	11.5
—	VC1-C216 to C320	6	5.5	5	4.5	4	3.5
—	VC1-C339 to C469	7	6.5	6	5.5	5	4.5

Table 12. VCA Evaporative Condensers

Model Number	No Discharge Hood		
	h=0'	h=2'	h=4'
VCA-122A to 191A	3.5	3	3
VCA-174A to 259A	5.5	5	4.5
VCA-261A to 322A	5	4.5	4
VCA-323A to 446A	6	5.5	5
VCA-300A to 512A	7	6.5	6
VCA-460A to 779A	9	8.5	7.5
VCA-662A to 1024A	10.5	10	9
VCA-S700A to S884A	10	9.5	8.5
VCA-920A to 1558A	12.5	12	11
VCA-302A to 661A	9	8	7.5
VCA-526A to 1010A	11.5	10.5	9.5
VCA-S870A to S1204A	13	12	11
VCA-605A to 1321A	13.5	12.5	11.5
VCA-930A to 2019A	15.5	14.5	14

Table 13. VFL and VCL Units

Model Number	No Discharge Hood			4' Discharge Hood		
	h=0'	h=2'	h=4'	h=0'	h=2'	h=4'
VFL-012-XXX	VCL-016 to 035	3	3	3	3	3
VFL-024-XXX	VCL-038 to 079	3	3	3	3	3
VFL-036-XXX	VCL-087 to 120	4.5	3.5	3	3	3
VFL-048-XXX	VCL-134 to 155	4.5	4	3.5	3.5	3
VFL-072-XXX	VCL-167 to 234	6	5.5	5	4.5	4
VFL-096-XXX	VCL-257 to 299	7	6.5	5.5	5.5	4.5

NOTES:

1. "d" value was calculated using the largest horsepower motor available.
2. Max "h" value is 4'. For units installed at height greater than 4' use "d" value for h = 4.



NOTE: If these guidelines do not address a specific situation or if the layout criteria cannot be met, please refer the application to your BAC Representative for review.

Table 14. Nexus® Modular Hybrid Cooler

Model Number	# of Modules	h=0'
NXF-0403N-CS2TT-H1	1	3 ⁽¹⁾
NXF-0403N-CS2TT-H2	2	3
NXF-0403N-CS2TT-H3	3	4
NXF-0403N-CS2TT-H4	4	4.75
NXF-0403N-CS2TT-H5	5	5.25
NXF-0403N-CS2TT-H6	6	5.5
NXF-0603N-CS2TT-J1	1	3 ⁽¹⁾
NXF-0603N-CS2TT-J2	2	3 ⁽¹⁾
NXF-0603N-CS2TT-J3	3	3
NXF-0603N-CS2TT-J4	4	3.5
NXF-0603N-CS2TT-J5	5	4
NXF-0603N-CS2TT-J6	6	4.25

Table 15. Vertex® Evaporative Condenser

Model Number	No Discharge Hood		
	h=0'	h=2'	h=4'
VRC-0213B to 0364B-1012N-XA	7	6.5	6
VRC-0327B to 0553B-1018N-XA	9	8	7.5
VRC-0470B to 0727B-1024N-XA	10.5	5	9
VRC-0653B to 1106B-1036N-XA	12.5	11.5	11
VRC-0214B to 0469B-1212N-XA	9	8	7.5
VRC-0374B to 0717B-1218N-XA	11	10.5	9.5
VRC-0429B to 0939B-1224N-XA	13	12	10.5
VRC-0661B to 1434B-1236N-XA	15.5	14.5	13.5
VRC-0241B to 0383B-1012N-XB	8	7	6
VRC-0357B to 0565B-1018N-XB	8	7	6.5
VRC-0482B to 0766B-1024N-XB	11.5	10.5	9.5
VRC-0713B to 1131B-1036N-XB	11	10	9.5
VRC-0281B to 0448B-1212N-XB	9	8	7.5
VRC-0417B to 0662B-1218N-XB	8.5	8	7
VRC-0562B to 0895B-1224N-XB	13	12	11
VRC-0835B to 1324B-1236N-XB	11.5	11	10.5



NOTES FOR THE NEXUS® MODULAR HYBRID COOLER:

1. Minimum dimension adjusted to allow for access to the EC Fan System via the swing-out access door.
2. To allow for the future removal of the drift eliminators and water collection, extra space may be required on the basin side of the unit. For NXF-0403x units this required distance is 4'. For NXF-0603x units this required distance is 6'.
3. All dimensions are measured from base of unit.
4. For accessing the iPilot™ Control System on the end of a unit (Face A or B), 38" of free space is required.
5. Calculations are based on a maximum air velocity of 300 fpm when considering a single, solid wall. These calculations also assume a maximum air envelope width of 1.5' wider than the unit on each side.



NOTES FOR THE VERTEX® EVAPORATIVE CONDENSER

1. "d" value was calculated using the largest horsepower motor available.
2. Max "h" value is 4'. For units installed at height greater than 4' use "d" value for h = 4.

Well Layout

The following method is used to determine the minimum acceptable dimension "d" for units installed in a well layout.

The maximum allowable downward air velocity for a well installation is 400 FPM. The downward velocity is determined using the following equation:

$$\text{Downward Air Velocity} = \text{Airflow} / \text{Usable Well Area} < 400 \text{ FPM}$$

The usable well area at each air intake face is defined as illustrated in Figures 5, 6, and 7.

$$\text{Usable Well Area} = d(L+2s)+2(s * 1'), \text{ where:}$$

"d" – minimum acceptable distance between the air intake of the unit and the wall of the well in feet

"L" – length of the air intake of the unit in feet

"s" – Distance usable well area extends beyond unit length (L).

Maximum value for "s" is 4'. If greater than 4' clearance beyond the sides of the unit, use s = 4

$$\text{Therefore, } d = \frac{\left(\frac{\text{Airflow}^{[1]}}{400} \right) - 2s}{L + 2s}$$

The minimum acceptable distance "d" for well installations is tabulated in **Tables 16-29** on pages J85-J88.




Figure 5. Plan View of Dual Air Intake Unit in a Well Enclosure




Figure 6. Plan View of Single Air Intake Unit in a Well Enclosure




Figure 7. Plan View of Single Air Intake And Horizontal Discharge Units in a Well Enclosure



NOTES:

1. The louver face airflow for the FXV Closed Circuit Cooling Towers and CXVB Evaporative Condensers is 70% of the total unit airflow. The remaining 30% of the airflow enters the unit through the top of the coil section. Expand note 1 throughout document: Airflow value for crossflow dual air intake units should be 50% of total unit airflow. For FXV3 models, use 35% of total unit airflow.

Example: Model FXV-0809B-28D-M in a Well

What is the minimum distance between the air intake of the FXV-0809-28D-M and the enclosure wall of the well?

Unit Airflow = 56,670 CFM

Note: Air intake airflow is 70% of total unit airflow for FXV Closed Circuit Cooling Towers

Airflow = Unit Airflow * 0.70 = 56,670 * 0.70

Airflow = 39,669 CFM

L = 9'

s = 4'

Solving for "d",

$$d = \frac{\left(\frac{\text{Airflow}}{400} \right) - 2s}{L + 2s}$$

$$d = \frac{\left(\frac{39,669}{400} \right) - (2^4)}{9 + (2^4)}$$

$$d = 5.36'$$

This is rounded up to the next 0.5' increment. Therefore the air intake should be no less than 5.5' from the enclosure walls.

Example: Model VF1-144-31Q in a Well

If the VF1-144-31Q has a 4' tapered discharge hood, what is the minimum distance between the air intake of the VF1-144-31Q and the enclosure wall in a well?

Unit Airflow = 86,500 CFM

L = 11' 8" = 11.67'

s = 4'

400 FPM = maximum allowable air downward velocity for a VF1 with a tapered discharge hood

Solving for "d",

$$d = \frac{\left(\frac{\text{Airflow}}{400} \right) - 2s}{L + 2s}$$

$$d = \frac{\left(\frac{86,500}{400} \right) - (2^4)}{11.67' + (2^4)}$$

$$d = 10.59'$$

This is rounded up to the next 0.5' increment. Therefore the air intake should be no less than 11' from the enclosure walls.

Minimum Acceptable Air Intake Distance "d" (ft) in a Well

Table 16. Series 3000 Cooling Towers

Model Number	One Cell	Two Cell	Three Cell	Four Cell
S3E/XES3E-8518-05x	6	8.5	9.5	10.0
S3E/XES3E-8518-06x	7.5	10.5	11.5	12.5
S3E/XES3E-8518-07x	9.0	12.0	13.5	14.5
S3E/XES3E-1020-06x	7.5	10.0	11.0	12.0
S3E/XES3E-1020-07x	9.0	12.0	13.0	14.0
S3E/XES3E-1222-06x	8.0	10.0	11.0	11.5
S3E/XES3E-1222-07x	10.5	13.5	14.5	15.5
S3E/XES3E-1222-10x	13.5	17.0	19.0	19.5
S3E/XES3E-1222-12x	14.5	18.0	20.0	21.0
S3E/XES3E-1222-13x	14.5	18.5	20.5	21.5
S3E/XES3E-1222-14x	16.5	21.0	23.0	24.0
S3E/XES3E-1424-07x	10.5	13.5	14.5	15.0
S3E/XES3E-1424-12x	16.0	19.5	21.0	22.0
S3E/XES3E-1424-13x	16.5	20.0	22.0	22.5
S3E/XES3E-1424-14x	17.0	21.0	22.5	23.5

Table 17. Series 1500 Cooling Towers

Model Number	One Cell	Two Cell	Three Cell	Model Number	One Cell	Two Cell	Three Cell
S15E/XE15E-1285-06x	7.0	9.5	10.5	S15E/XE15E-1212-11x	13.5	17.0	18.5
S15E/XE15E-1285-07x	8.0	11.0	12.0	S15E/XE15E-1212-12x	13.5	17.5	19.0
S15E/XE15E-1285-09x	9.0	12.5	14.0	S15E/XE15E-1218-07x	11.0	13.5	14.0
S15E/XE15E-1285-10x	10.5	14.0	15.5	S15E/XE15E-1218-09x	13.0	15.5	17.0
S15E/XE15E-1212-07x	9.5	12.0	13.0	S15E/XE15E-1218-10x	15.0	18.0	19.0
S15E/XE15E-1212-09x	11.5	14.5	15.5	S15E/XE15E-1218-11x	15.5	18.5	19.5
S15E/XE15E-1212-10x	13.0	16.0	18.0	S15E/XE15E-1218-12x	16.0	19.0	20.5

 **NOTES:**

1. "d" value was calculated using the largest horsepower motor available and 4' clearance on both sides of the units intake face. For units with lower horsepower, clearance may be able to be reduced. Contact your BAC Sales Representative for support.

Minimum Acceptable Air Intake Distance "d" (ft) in a Well

Table 18. FXT Cooling Towers

Model Number	One Cell
FXT-0506A-X	3.5
FXT-0706B-X	5
FXT-0709B-X	6
FXT-0712B-X	7
FXT-0712C-X	8.5

Table 19. VTL Cooling Towers with or without a Tapered Discharge Hood

Model Number	One Cell
VTL-016-E to VTL-039-H	3
VTL-045-H to VTL-079-K	3
VTL-082-K to VTL-095-K	4
VTL-103-K to VTL-137-M	5.5
VTL-152-M to VTL-227-O	7
VTL-245-P to VTL-272-P	8.5

Table 20. VT0 and VT1 Cooling Towers with or without a Tapered Discharge Hood

Model Number	One Cell
VT0-12-E to VT0-176-0	4.5
VT1-N209-P to VT1-N255-P	6.5
VT1-N301-Q to VT1-N395-R	8
VT1-N418-P to VT1-N510-P	8.5
VT1-M316-O to VT1-M420-R	10
VT1-M431-O to VT1-M610-R	11.5
VT1-M632-O to VT1-M840-R	12.5
VT1-M948-O to VT1-M1260-R	14
VT1-275-P to VT1-415-R	11
VT1-416-O to VT1-600-P	12.5
VT1-550-P to VT1-830-R	14
VT1-825-P to VT1-1335-S	16.5

Table 21. FXV Closed Circuit Cooling Tower and HXV Hybrid Cooler

Model Number	One Cell
FXV-0806A	3.5
FXV-0806B, FXV-0809A	5
FXV-0809B	5.5
FXV-0812A	6
FXV-0812B, FXV-0818A	7.5
FXV-0818B, FXV-1212B, HXV-1212N-1B	9
FXV-1212C, HXV-1212N-1C	10
FXV-1218B, HXV-1218N-1B	10
FXV-1218C, HXV-1218N-1C	11.5

Table 22. FXV3 and CXVT Units

FXV3 Model Number	CXVT Model Number	One Cell	Two Cell
FXV3-1224-X-X	CXVT-x-1224-x and XECXVTx-1224-x	11.5	14.5
FXV3-1426-X-X	CXVT-x-1426-x and XECXVTx-1426-x	13.5	16.5
—	CXVT-x-2424-x and XECXVTx-2424-x	—	14.5
—	CXVT-x-2826-x and XECXVTx-2826-x	—	16.5

Table 23. CXVB Evaporative Condenser

Model Number	One Cell	Two Cell
CXVB-X-0806-X	4.5	—
CXVB-X-0809-X	5.5	—
CXVB-X-0812-X	7	—
CXVB-X-0818-X	8	—
CXVB-X-1212-X	9.5	14
CXVB-X-1218-X	11	15

Table 24. VCA Evaporative Condensers

Model Number	One Cell
VCA-122A to 191A	3.5
VCA-174A to 259A	5.5
VCA-261A to 322A	6.5
VCA-323A to 446A	6.5
VCA-300A to 512A	9
VCA-460A to 779A	10.5
VCA-662A to 1024A	11
VCA-S700A to S884A	11
VCA-920A to 1558A	12.5
VCA-302A to 661A	11
VCA-526A to 1010A	13
VCA-S870A to S1204A	14
VCA-605A to 1321A	14
VCA-930A to 2019A	15.5

Table 26. Vertex® Evaporative Condensers

Model Number	One Cell
VRC-0213B to 0364B-1012N-XA	9
VRC-0327B to 0553B-1018N-XA	10.5
VRC-0470B to 0727B-1024N-XA	11
VRC-0653B to 1106B-1036N-XA	12.5
VRC-0214B to 0469B-1212N-XA	11.5
VRC-0374B to 0717B-1218N-XA	13
VRC-0429B to 0939B-1224N-XA	14.5
VRC-0661B to 1434B-1236N-XA	15.5
VRC-0241B to 0383B-1012N-XB	10
VRC-0357B to 0565B-1018N-XB	9
VRC-0482B to 0766B-1024N-XB	12.5
VRC-0713B to 1131B-1036N-XB	11
VRC-0281B to 0448B-1212N-XB	11
VRC-0417B to 0662B-1218N-XB	9.5
VRC-0562B to 0895B-1224N-XB	14
VRC-0835B to 1324B-1236N-XB	11.5

Table 25. VFL and VCL Units with or without a Tapered Discharge Hood

Model Number	One Cell
VFL-012-XXX	VCL-016 to 035
VFL-024-XXX	VCL-038 to 079
VFL-036-XXX	VCL-087 to 120
VFL-048-XXX	VCL-134 to 155
VFL-072-XXX	VCL-167 to 234
VFL-096-XXX	VCL-257 to 299

Table 27. VF1 and VC1 Units with or without a Tapered Discharge Hood

Model Number	One Cell
VF1-009-XXX	VC1-10 to 25
VF1-018-XXX	VC1-30 to 65
VF1-027-XXX	VC1-72 to 90
VF1-036-XXX	VC1-100 to 135
VF1-048-XXX	VC1-150 to 205
VF1-072-XXX	VC1-N208 to N230
VF1-096-XXX	VC1-N243 to N315
VF1-144N-XXX	VC1-N338 to N470
VF1-192-XXX	—
VF1-288N-XXX	—
VF1-1012N-XXXXX-XX	—
VF1-1018N-XXXXX-XX	—
VF1-1024N-XXXXX-XX	—
VF1-1036N-XXXXX-XX	—
VF1-144-XXX	VC1-386 to 516
VF1-216-XXX	VC1-540 to 804
VF1-288-XXX	VC1-772 to 1032
VF1-432-XXX	VC1-1158 to 1608
—	VC1-C216 to C320
—	VC1-C339 to C469

Table 28. Nexus® Modular Hybrid Cooler

Model Number	# of Modules	d Value
NXF-0403N-CS2TT-H1	1	3.5
NXF-0403N-CS2TT-H2	2	4.75
NXF-0403N-CS2TT-H3	3	5.5
NXF-0403N-CS2TT-H4	4	5.75
NXF-0403N-CS2TT-H5	5	6
NXF-0403N-CS2TT-H6	6	6
NXF-0603N-CS2TT-J1	1	3 ⁽¹⁾
NXF-0603N-CS2TT-J2	2	3.75
NXF-0603N-CS2TT-J3	3	4
NXF-0603N-CS2TT-J4	4	4.5
NXF-0603N-CS2TT-J5	5	4.5
NXF-0603N-CS2TT-J6	6	4.75

Table 29. TrilliumSeries® Adiabatic Cooler

Model Number	d Value
TRF-1010N-C80xx17E	3.2
TRF-1014N-C80xx26E	4.1
TRF-1018N-C80xx34E	4.8
TRF-1022N-C80xx43E	5.4
TRF-1026N-C80xx51E	5.7
TRF-1030N-C80xx60E	6
TRF-1034N-C80xx68E	6.3
TRF-1038N-C80xx77E	6.5
TRF-1010N-C60Fx17E	3.3
TRF-1014N-C60Fx26E	4.3
TRF-1018N-C60Fx34E	5
TRF-1022N-C60Fx43E	5.6
TRF-1026N-C60Fx51E	5.9
TRF-1030N-C60Fx60E	6.2
TRF-1034N-C60Fx68E	6.5
TRF-1038N-C60Fx77E	6.7

**NOTES FOR THE NEXUS® MODULAR HYBRID COOLER:**

1. Minimum dimension adjusted to allow for access to the EC Fan System via the swing-out access door.
2. To allow for the future removal of the drift eliminators and water collection, extra space may be required on the basin side of the unit. For NXF-0403x units this required distance is 4'. For NXF-0603x units this required distance is 6'.
3. All dimensions are measured from base of unit.
4. For accessing the iPilot™ Control System on the end of a unit (Face A or B), 38" of free space is required.
5. Calculations are based on a maximum air velocity of 400 fpm when considering a well installation. These calculations also assume a maximum air envelope width of 1.5' wider than the unit on each side.

**NOTE:**

1. If a well layout for the TrilliumSeries® Dry Cooler is required, contact your local BAC Representative.

Louvered or Slotted Wall Installations

Check to see if the layout meets the requirements for a well installation.

If the criteria for the well installation are met, the layout is satisfactory.

If the layout does not satisfy the criteria for the well installation, analyze the layout as follows:

1. Air intake requirements:

- a. Units should be arranged within the enclosure such that the air intake directly faces the louver or slot locations as shown in **Figures 8 and 9**, with a minimum distance of three feet.
- b. If the available space does not permit the unit to be arranged with the air intakes facing the louvered or slotted walls and the enclosure cannot be modified to permit such an arrangement, consider the alternative illustrated in **Figures 10 and 11** on the following page. This arrangement should be restricted to one-cell or two-cell installations. The usable area of the louvers is only the length extending beyond the width of the unit.

2. Louver requirements:

- c. Louvers must provide at least 50% net free area to ensure that the unit airflow is not reduced due to friction or dynamic losses and that sufficient air is drawn through the openings and not downward from above.
- d. The required total louver or slot area is based on drawing the airflow through the net free area of the louvers at a velocity of 600 FPM or less.
- e. Locate the louver area in the walls of the enclosure such that air flows uniformly to the air intakes.
- f. If the unit is elevated to ensure the discharge is at the same level or above the top of the enclosure, it is acceptable to extend the louvered or slot area below the base of the units up to 2' if needed to achieve the minimum gross louver area. To calculate air velocity through the louver, the usable louvered or slot area may extend beyond the ends of the unit by a value 1/2 the unit length (L), with 6' maximum on either side. the unit by a value 1/2 the unit length (L), with 6' maximum on either side. air velocity through the louver, the usable louvered or slot area may extend beyond the ends of the unit by a value 1/2 the unit length (L), with 6' maximum on either side.




Figure 8. Plan View of Dual Air Intake Unit in Enclosure with Louvered Walls




Figure 9. Plan View of Single Air Intake Unit in Enclosure with Louvered Walls




Figure 10. Plan View of Dual Air Intake Unit with Alternate Louver Arrangement




Figure 11. Plan View of Single Air Intake Unit with Alternate Louver Arrangement

Calculate the louver velocity as follows:

$$\text{Louver Velocity} = \frac{\text{Airflow}}{\% \text{ Louver Free Area} * \text{Usable Louver Area}} \leq 600 \text{ FPM}$$

"e" - Distance usable louvered area may extend beyond unit length (L) as illustrated in **Figures 8 and 9**. The value for "e" is 1/2 the unit length (L), not to exceed 6'.

Example: S3E-1222-06M-2 in a Louvered Enclosure

The enclosure is 27.5' long by 38' wide by 10' tall. The enclosure walls are equal in elevation to the unit discharge height. The louvers are 70% free area and 3' 0" from the air intake of the tower. The louvers extend the full width of the enclosure (38') on both air intake ends and they extend 9' vertically of the 10' enclosure height.

Unit Airflow = 120,200 CFM x 2 cells = 240,400 CFM

Note: Series 3000 units are dual air intake units, therefore the air intake airflow is half of the total unit airflow.

Airflow = Total Unit Airflow/2 = 240,400/2 = 120,200 CFM

$L = 23' 10" = 23.83'$, $L/2 = 23.83/2 = 11.9'$

$L/2 > 6'$, therefore $e = 6'$

Maximum Usable Louver Length = $L + 2e = 23.83' + (2*6) = 35.83'$ (of total 38' louver length)

Area = $35.83*9 = 322.47 \text{ ft}^2$

$$\begin{aligned} \text{Louver Velocity} &= \frac{\text{Airflow}}{(\% \text{ Louver Free Area}) * (\text{Usable Louver Area})} \\ &= \frac{120,200}{0.70 * 322.47} \\ &= 527 \text{ FPM} \end{aligned}$$

Therefore, louver sizing is sufficient because $532 \text{ FPM} < 600 \text{ FPM}$ maximum allowable louver velocity.

Indoor Installation Layout Guidelines: Applicable for Series V Centrifugal Fan Products Only (VT0, VT1, VTL, VF1, VC1, VCL, & VFL)

1. Air intake requirements:

- a. Louvers must have at least 50% net free area.
- b. Install the cooling tower with the limitations shown in Figure 12 for uniform air distribution—
- c. Determine the total louver or slot area required based on drawing the total unit airflow through the net free area of the louver at a velocity of 800 FPM or less.
- d. The louver or slot area should be located in the walls of the enclosure so that air flows uniformly to all air intakes.
- e. It is acceptable to extend the louvered or slot area below the base of the unit if needed to achieve the minimum gross free area. The usable louvered or slot area may also be extended beyond the ends of the tower by a maximum 4'.
- f. As a general rule, axial fan units cannot be located indoors.

2. Ductwork requirements:

- g. Air velocities in the intake duct should be kept below 800 FPM to hold static pressure losses to a minimum and ensure a uniform supply of air to all fans. In general the maximum allowable External Static Pressure (ESP) on Series V centrifugal fan units is 1/2". Consult the factory for any ESP greater than 1/2".
- h. Air velocities in the discharge duct(s) should not exceed 1,000 FPM to reduce friction losses in the duct, and more importantly, to ensure uniform air distribution through the unit.
- i. Turns in intake or discharge ducts should be avoided. Where turns must be used, velocities should be minimized in the vicinity of the turn. Turns in discharge ducting should be designed in accordance with the "2/3's rule" shown in Figure 13a and 13b.
- d. Where individual fan sections are to be cycled for capacity control, each fan section must be ducted as a separate system on both intake and discharge to avoid recirculation within the ductwork. All ductwork systems should be symmetrical to ensure that each fan section operates against the same ESP.
- e. Access doors must be provided in both the intake and discharge ducts.
- f. When multi-cell units are located indoors with the room as the plenum, the installation must be operated as a single unit to avoid pulling air through an idle cell.




Figure 12. Plan View of Single Air Intake Unit in Enclosure with Louvered Walls and Closed Top Installation




Figure 13a. Elevation Side View of Ducted Unit Enclosure




Figure 13b. Elevation Front View of Ducted Unit

Multi-Cell Installation

Unit Orientation: Multiple cells create a “wall” of moist discharge air which could easily be swept into the air intakes due to prevailing wind. To minimize the potential of recirculation of the discharge air, the units should be situated with adequate spacing between air intakes. For critical cooling applications where multiple cells cannot be down at once, it is advisable to place units in pairs so any maintenance can be completed without shutting off adjacent cells.

When multiple cells are arranged with the air intakes facing each other, the distance between air intakes should follow the equation below:

$M = (2 * d) + (\text{number of cells per module})$, where “d” is obtained from the appropriate model for "Installations Adjacent to a Building or Wall(s)" on page J76.




Figure 14. Plan View of Multi-Cell Units with Air Intakes Facing Each Other

Example: Model S3E-1222-14R (see Figure 14)

There are two banks of three cell unit modules on a roof. There are no enclosures surrounding the unit installation. The two banks of units have air intakes facing each other. What is the minimum distance "M" between banks of units?

From Table 1 on page J78, $d = 15'$

$$\begin{aligned} M &= (2 * d) + (\text{number of units per module}) \\ &= (2 * 15) + 3 \\ &= 33 \text{ feet} \end{aligned}$$

The calculated "M" dimension of 33 feet will minimize the potential for recirculation of the discharge air.

Group units in two cell or three cell modules, spaced at least one unit length between adjacent end walls to allow fresh air to circulate around each group, as shown in **Figure 15**.




Figure 15. Plan View of Recommended Multi-cell Installation

In the extreme case, when multiple cells are arranged with the air intakes facing each other in a well, the dimensions between the cells should follow the following requirements.

1. **Enclosure:** The bottom 3 feet of the well should be louvered a minimum of 50% net free area to allow air flow under the units as shown in **Figure 17**.
2. **Support:** The units should be raised off the roof deck to allow fresh air to flow under to the air intakes between the bank of cells.
3. **The distance between the cells should be determined using the following method:**
 - a. Determine the maximum airflow drawn from the louvered area using the following equation:

$$\text{CFM drawn through the louvers} = \text{Louver Velocity} * \% \text{ Louver Free Area} * \text{Usable Louver Area}$$

$$\text{CFM drawn through the louvers} = 600 \text{ FPM} * \% \text{ Louver Free Area} * \text{Usable Louver Area}$$
 - b. Determine the CFM drawn from the top of the enclosure using the following equation:

$$\text{CFM drawn from the top of the enclosure} = 400 \text{ FPM} * \text{Usable Well Area}$$




Figure 16. Plan View of Multi-cell Installation




Figure 17. Elevation View of Recommended Enclosure

Example: (10) S3E-1222-14S (See Figure 16)

Bottom 3' of enclosure is louvered with 50% net free area. What is the minimum distance "D" between the banks of cells.

Unit Airflow = 244,030 CFM * 10 cells = 2,440,300 CFM

$$L = 11' 10" = 11.83'$$

$$\text{Usable Length} = (\text{Number of cells} * L) + (\text{Number of Openings} * L) + 4' + 4'$$

$$\begin{aligned} &= (5 * 11.83) + (1 * 11.83) + 4 + 4 \\ &= 78.98' \text{ feet} \end{aligned}$$

$$\text{Usable Width} = 4D$$

$$\text{CFM Drawn Through Louvers} = \text{Louver Velocity} * \% \text{ Louver Free Area} * \text{Usable Louver Area}$$

$$\begin{aligned} &= \text{Louver Velocity} * \% \text{ Louver Free Area} * \text{Perimeter of the Enclosure} * \text{Height of Louvered Wall} \\ &= \text{Louver Velocity} * \% \text{ Louver Free Area} * [2(\text{Usable Length} + \text{Usable Width}) * \text{Louver Height}] \\ &= 600 * 0.5 * [2(78.98 + 4D) * 3] \\ &= 142,164 + 7,200D \end{aligned}$$

$$\text{CFM Drawn from Top of the Enclosure} = \text{Downward Velocity} * \text{Usable Area}$$

$$\begin{aligned} &= \text{Downward Velocity} * (\text{Usable Length} * \text{Usable Width}) \\ &= 400 * 78.98 * 4D \\ &= 400 * 4D * 80 \\ &= 126,368D \end{aligned}$$

$$\text{Total CFM} = \text{CFM Drawn through louvers} + \text{CFM Drawn from Top of the Enclosure}$$

$$2,449,300 = 142,164 + 7,200D + 126,368D$$

$$133,568D = 2,298,136$$

$$D = 17.21'$$

The "Layout Guidelines" describe several typical site situations involving cooling products. If these guidelines do not cover a particular situation or if the layout criteria cannot be met, please refer the application to your local BAC Representative for review. Please indicate prevailing wind direction, geographic orientation of the unit(s), and other factors such as large buildings and other obstructions that may influence layout decisions.