



PLAN VIEW

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 40% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

Model Number	Shipping Weight	Operating Weight
PT2-1218A-1x4	43750	81300
PT2-1218A-2x4	46550	84100
PT2-1218A-3x4	48800	86350
PT2-1218A-4x4	49790	87890
PT2-1218A-5x4	57174	95824

ORDER IN A STEEL

DATE:



BALTIMORE AIRCOIL COMPANY

**Unit Support
PT2 24'x36' Quad Cell**

DRAWING NUMBER: