



Model Number	Approx, Shipping Weight	Approx, Operating Weight
PCC-0269-1012N030	12600	18550
PCC-0208-1012N010	12730	18710
PCC-0233-1012N015	12860	18840
PCC-0272-1012N020	14770	20830
PCC-0281-1012N025	14310	20370
PCC-0295-1012N030	14360	20420
PCC-0315-1012N040	15070	21160
PCC-0323-1012N030	17890	24140
PCC-0246-1012N010	18400	24700
PCC-0328-1012N030	18690	24990

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PCC Evaporative Condenser
Tabulated Steel Support - Plan A**

DRAWING NUMBER:
SS-PCI-1012