



Model Number	Approx, Shipping Weight	Approx, Operating Weight
PCC-0249-1212N010	16780	24310
PCC-0265-1212N015	15420	22870
PCC-0293-1212N015	19000	26660
PCC-0309-1212N020	17780	25370
PCC-0330-1212N025	17810	25400
PCC-0346-1212N025	20100	27830
PCC-0365-1212N030	20150	27880
PCC-0396-1212N040	20340	28060
PCC-0355-1212N025	21200	29040
PCC-0375-1212N030	21250	29090
PCC-0395-1212N040	20270	28040
PCC-0406-1212N040	21440	29280

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PCC Evaporative Condenser
Tabulated Steel Support - Plan A**

DRAWING NUMBER:
SS-PCI-1212