



PLAN VIEW

Model Number	Approx. Shipping Weight	Approx. Operating Weight
PCC-0990-1236N080	46250	68370
PCC-0756-1236N030	47730	69970
PCC-0875-1236N040	52310	74830
PCC-1054-1236N080	53050	75570
PCC-1119-1236N100	53260	75780
PCC-0931-1236N040	59510	82580
PCC-1026-1236N060	60010	83080
PCC-1073-1236N080	57290	80170
PCC-1135-1236N080	63790	87090
PCC-1171-1236N100	60460	83530
PCC-1208-1236N100	64000	87300
PCC-1268-1236N120	64200	87500

- Notes
- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
 - 2) Operating weight and weight loading are for units with water level in basin at overflow.
 - 3) Unit support beams and anchor bolts to be designed and furnished by others.
 - 4) Support beams must be flush and level at top.
 - 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
 - 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



**PCC Evaporative Condenser
Tabulated Steel Support - Plan A**

DRAWING NUMBER:
SS-PCI-1236