



PLAN VIEW



ELEVATION VIEW

Model Number	Approx. Shipping Weight	Approx. Operating Weight
PCC-0996-2424N040	67840	98000
PCC-1060-2424N060	62410	92240
PCC-1172-2424N060	76750	107390
PCC-1236-2424N080	71860	102220
PCC-1320-2424N100	71980	102340
PCC-1384-2424N100	81150	112050
PCC-1460-2424N120	81350	112250
PCC-1584-2424N160	82100	113000
PCC-1420-2424N100	85530	116910
PCC-1500-2424N120	85730	117110
PCC-1580-2424N160	81810	112890
PCC-1624-2424N160	86490	117860

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PCC Evaporative Condenser
Tabulated Steel Support - Plan A**

DRAWING NUMBER:
SS-PCI-2424