



PLAN VIEW

Model Number	Approx. Shipping Weight	Approx. Operating Weight
PCC-1947-2436N160	92890	137130
PCC-1501-2436N060	95860	140340
PCC-1738-2436N080	105020	150060
PCC-2092-2436N160	106500	151540
PCC-2223-2436N200	106920	151960
PCC-1848-2436N080	119410	165560
PCC-2037-2436N120	120410	166560
PCC-2132-2436N160	114970	160750
PCC-2254-2436N160	127970	174580
PCC-2325-2436N200	121310	167460
PCC-2400-2436N200	128390	174990
PCC-2518-2436N240	128790	175390

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PCC Evaporative Condenser  
Tabulated Steel Support - Plan A**

DRAWING NUMBER:  
**SS-PCI-2436**