



Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PCC-0494-1218N040	23050	34100	18730	4'-0 5/8"	17'-0"
PCC-0381-1218N015	23790	34910	19470	4'-8 1/8"	17'-7 1/2"
PCC-0441-1218N020	26080	37340	21760	4'-8 1/8"	17'-7 1/2"
PCC-0531-1218N040	26450	37710	22130	4'-8 1/8"	17'-7 1/2"
PCC-0564-1218N050	26550	37810	22240	4'-8 1/8"	17'-7 1/2"
PCC-0469-1218N020	29680	41210	25360	4'-0 5/8"	17'-0"
PCC-0517-1218N030	29930	41460	25610	4'-0 5/8"	17'-0"
PCC-0541-1218N040	28570	40010	24250	4'-0 5/8"	17'-0"
PCC-0572-1218N040	31820	43460	27500	4'-0 5/8"	17'-0"
PCC-0590-1218N050	30150	41680	25840	4'-0 5/8"	17'-0"
PCC-0609-1218N050	31920	43570	27610	4'-0 5/8"	17'-0"
PCC-0639-1218N060	32020	43670	27710	4'-0 5/8"	17'-0"

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches.
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the P-Series Counterflow Induced Draft Coil Products rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 8) M = Motor location

Right Hand Unit

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PCC Evaporative Condenser
Tabulated Unit Print**

DRAWING NUMBER:
UP-PCC-1218