



Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PCC-0980-1236N080	46250	68370	18730	4'-0 5/8"	18'-0"
PCC-0756-1236N030	47730	69970	19470	4'-8 1/8"	18'-7 1/2"
PCC-0875-1236N040	52310	74830	21760	4'-8 1/8"	18'-7 1/2"
PCC-1054-1236N080	53050	75570	22130	4'-8 1/8"	18'-7 1/2"
PCC-1119-1236N100	53260	75780	22240	4'-8 1/8"	18'-7 1/2"
PCC-0931-1236N040	59510	82580	25360	4'-0 5/8"	18'-0"
PCC-1026-1236N060	60010	83080	25610	4'-0 5/8"	18'-0"
PCC-1073-1236N080	57290	80170	24250	4'-0 5/8"	18'-0"
PCC-1135-1236N080	63790	87090	27500	4'-0 5/8"	18'-0"
PCC-1171-1236N100	60460	83530	25840	4'-0 5/8"	18'-0"
PCC-1208-1236N100	64000	87300	27610	4'-0 5/8"	18'-0"
PCC-1268-1236N120	64200	87500	27710	4'-0 5/8"	18'-0"

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches.
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the P-Series Counterflow Induced Draft Coil Products rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 8) M = Motor location

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

**PCC Evaporative Condenser
Tabulated Unit Print**

DRAWING NUMBER:
UP-PCC-1236