


NOTES:

1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
2. UNLESS OTHERWISE INDICATED ALL CONNECTIONS 3 INCHES AND SMALLER ARE MPT AND CONNECTIONS 4 INCHES AND LARGER ARE BEVELLED FOR WELDING AND GROOVED FOR VICTAULIC CONNECTION.
3. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.
4. PRE-FABRICATION OF FINAL CONNECTING PIPEWORK IS NOT RECOMMENDED.
5. DO NOT SUPPORT PIPING FROM COOLING TOWER. ALL NECESSARY PIPE SUPPORTS ARE TO BE SUPPLIED BY OTHERS.

* UNIT SHIPS IN ONE PIECE.

MODEL NO.	APPROX. SHPG. WEIGHT	APPROX. OPER. WEIGHT	HEAV. SECT. (PAN)	A	H
VTO-32-H	1230	1590	1230 *	6'-7 7/8"	7'-6 1/8"
VTO-41-J	1290	1650	1290 *	6'-7 7/8"	7'-6 1/8"
VTO-52-J	1540	1780	870	8'-1 7/8"	9'-0 1/8"
VTO-57-K	1550	1790	880	8'-1 7/8"	9'-0 1/8"



B.A.C.
ORDER NO:



BALTIMORE AIRCOIL
COMPANY

COOLING TOWER

DATE:

DRAWING NUMBER:
BAC-9104 A

B