



**NOTES:**

1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
2. UNLESS OTHERWISE INDICATED ALL CONNECTIONS 3 INCHES AND SMALLER ARE MPT AND CONNECTIONS 4 INCHES AND LARGER ARE BEVELLED FOR WELDING AND GROOVED FOR VICTAULIC CONNECTION.
3. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.
4. PRE-FABRICATION OF FINAL CONNECTING PIPEWORK IS NOT RECOMMENDED.
5. DO NOT SUPPORT PIPING FROM COOLING TOWER. ALL NECESSARY PIPE SUPPORTS ARE TO BE SUPPLIED BY OTHERS.

MODEL NO.	APPROX. SHPG. WEIGHT	APPROX. OPER. WEIGHT	HEAV. SECT. (PAN)	A	H
VTO-65-J	2000	2580	1070	8'-1 7/8"	9'-0 1/8"
VTO-75-K	2010	2590	1080	8'-1 7/8"	9'-0 1/8"
VTO-78-K	2130	2710	1080	9'-7 7/8"	10'-6 1/8"
VTO-88-L	2190	2770	1140	9'-7 7/8"	10'-6 1/8"

B.A.C.  
ORDER NO:

DATE:



BALTIMORE AIRCOIL  
COMPANY

COOLING TOWER

DRAWING NUMBER:  
BAC-9105 A

C