



- IPS BEVELED FOR WELDING.
- Ⓜ FAN MOTOR LOCATION.
- † PAN IS HEAVIEST SECTION.

| MODEL NO. | APPROX. SHIPPING WEIGHT | APPROX. OPERATING WEIGHT | HEAVIEST SECTION (COIL) | F | H |
|-----------|-------------------------|--------------------------|-------------------------|---------|-------------|
| VC1-1158 | 45710 | 70450 | † 15340 | 33 1/4" | 12'-11 1/2" |
| VC1-1224 | 45910 | 70650 | † 15540 | 33 1/4" | 12'-11 1/2" |
| VC1-1366 | 52120 | 77520 | 18290 | 42 1/2" | 13'-8 3/4" |
| VC1-1430 | 52200 | 77600 | 18290 | 42 1/2" | 13'-8 3/4" |
| VC1-1496 | 58420 | 84480 | 21400 | 51 3/4" | 14'-6" |
| VC1-1608 | 59180 | 85240 | 21400 | 51 3/4" | 14'-6" |

NOTES:

1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
2. UNLESS OTHERWISE INDICATED, ALL CONNECTIONS 6 INCHES AND SMALLER ARE MPT AND CONNECTIONS 8 INCHES AND LARGER ARE BEVELED FOR WELDING.
3. DIMENSIONS SHOWING LOCATION OF COIL CONNECTIONS ARE APPROXIMATE AND SHOULD NOT BE USED FOR PREFABRICATION OF CONNECTING PIPING.
4. SPRAY WATER, OVERFLOW AND COIL CONNECTIONS ARE PROVIDED ON BOTH ENDS OF THE UNIT. ONLY ONE MAKE-UP CONNECTION IS FURNISHED, ON THE END INDICATED.
5. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.

B.A.C.
ORDER NO:
DATE:



BALTIMORE AIRCOIL
COMPANY

EVAPORATIVE CONDENSER
RH UNIT

DRAWING NUMBER:
BAC-9837 A

A