



PLAN VIEW

ELEVATION VIEW

Model Number	Shipping Weight	Operating Weight
PT2-1218A-1xT	21500	40270
PT2-1218A-2xT	22900	41670
PT2-1218A-3xT	25850	44620
PT2-1218A-4xT	24620	43918
PT2-1218A-5xT	27762	47060

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 40% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

BEAM IN STEEL



**BALTIMORE AIRCOIL COMPANY**

**Unit Support  
PT2 24'x18' Two Cell**

DRAWING NUMBER:

DATE: