



Model Number	Approx, Shipping Weight	Approx, Operating Weight
PCC-0177-0718N010	12260	19130
PCC-0214-0718N020	12460	19330
PCC-0222-0718N015	13670	20630
PCC-0267-0718N030	14020	20970
PCC-0232-0718N015	14140	21130
PCC-0278-0718N030	14960	21980
PCC-0300-0718N040	15300	22320
PCC-0324-0718N020	16190	23280
PCC-0349-0718N020	20370	27700

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches. Weights are in pounds and include options and accessories.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PCC Evaporative Condenser  
Tabulated Steel Support - Plan A**

DRAWING NUMBER:  
**SS-PCI-0718**