



PLAN VIEW

ELEVATION VIEW

Model Number	Approx, Shipping Weight	Approx, Operating Weight
PFI-1236N-2DXDS-X2	41180	62510
PFI-1236N-2DXES-X2	42880	64300
PFI-1236N-3DXDS-X2	47390	71430
PFI-1236N-3DXES-X2	50140	74280
PFI-1236N-4DXDS-X2	54140	80890
PFI-1236N-4DXES-X2	57010	83850
PFI-1236N-5DXES-X2	57520	84710
PFI-1236N-6DXES-X2	66730	97460

Notes

- 1) Drawings are not to scale. All dimensions are in feet and inches, weights are in pounds. Refer to submittal drawings for actual dimensions and weights.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



**BALTIMORE AIRCOIL COMPANY**

**PFI Closed Circuit Cooling Tower  
Tabulated Steel Support - Plan A**

DRAWING NUMBER:  
**SS-PFI-1236**