



- Notes
- 1) Drawings are not to scale. Refer to submittal drawings for actual dimensions and weights. All dimensions are in feet and inches, Weights are in pounds.
 - 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
 - 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
 - 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
 - 5) Heaviest section is the combined weight of fan and coil sections, refer to the rigging and assembly manual for suggested lifting method.
 - 6) The area above the discharge must be unobstructed.
 - 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
 - 8) M = Motor location.
- Right Hand Unit

Model Number	Approx, Shipping Weight	Approx, Operating Weight	Heaviest Section Weight	F	H
PFI-1218N-2DXDS-X1	20450	31110	16410	4'-0 5/8"	17'-0"
PFI-1218N-2DXES-X1	21300	32010	17260	4'-8 1/8"	17'-7 1/2"
PFI-1218N-3DXDS-X1	23550	35570	19510	4'-0 5/8"	17'-0"
PFI-1218N-3DXES-X1	24930	36990	20890	5'-3 5/8"	18'-3"
PFI-1218N-4DXDS-X1	26930	40300	22890	4'-8 1/8"	17'-7 1/2"
PFI-1218N-4DXES-X1	28360	41780	24320	5'-11 1/8"	18'-10 1/2"
PFI-1218N-5DXES-X1	28620	42210	24570	6'-5 5/8"	19'-5"
PFI-1218N-6DXES-X1	33230	48580	29180	7'-1 1/8"	20'-0 1/2"

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

PFI Closed Circuit Cooling Tower Tabulated Unit Print

DRAWING NUMBER:
UP-PFI-1218