



Notes

- 1) Drawings are not to scale. Refer to submittal drawings for actual dimensions and weights. All dimensions are in feet and inches, Weights are in pounds.
- 2) Unless otherwise indicated, connections 3" and larger are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 8) M = Motor location.

Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PFI-2418N-2DXDS-X2	41320	62650	16410	4'-0 5/8"	18'-6"
PFI-2418N-2DXES-X2	43020	64450	17260	4'-8 1/8"	19'-1 1/2"
PFI-2418N-3DXDS-X2	47530	71570	19510	4'-0 5/8"	18'-6"
PFI-2418N-3DXES-X2	50290	74420	20890	5'-3 5/8"	19'-9"
PFI-2418N-4DXDS-X2	54280	81040	22890	4'-8 1/8"	19'-1 1/2"
PFI-2418N-4DXES-X2	57150	84000	24320	5'-11 1/8"	20'-4 1/2"
PFI-2418N-5DXES-X2	57670	84850	24570	6'-5 5/8"	20'-11"
PFI-2418N-6DXES-X2	66880	97600	29180	7'-1 1/8"	21'-6 1/2"

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

PFI Closed Circuit Cooling Tower Tabulated Unit Print

DRAWING NUMBER:
UP-PFI-2418