



NOTE:

1. FOR WEIGHT LOADING AND SUGGESTED STEEL SUPPORT REFER TO DRAWING BAC15036B FOR STANDARD STEEL ARRANGEMENT OR DRAWING BAC-15089B FOR UNITS BEING PROVIDED WITH VIBRATION RAILS.

MODEL NO.	APPROX. SHIPPING WEIGHT (LBS)	APPROX. OPERATING WEIGHT (LBS)	A	H
VTLO16-E	1100	1620	4'-0 3/4"	5'-1 1/4"
VTLO21-F	1140	1660	4'-0 3/4"	5'-1 1/4"
VTLO27-F	1220	1740	5'-7"	6'-6 1/4"
VTLO30-G	1250	1770	5'-7"	6'-6 1/4"
VTLO34-H	1290	1810	5'-7"	6'-6 1/4"
VTLO39-H	1390	1910	7'-1 5/16"	8'-1 13/16"

B.A.C. ORDER NO.	BALTIMORE AIRCOIL	COOLING TOWER	
DATE		DWG NO. BAC-15000B	A