


NOTE:

1. FOR WEIGHT LOADING AND SUGGESTED STEEL SUPPORT REFER TO DRAWING BAC15036B FOR STANDARD STEEL ARRANGEMENT OR DRAWING BAC-15090A FOR UNITS BEING PROVIDED WITH VIBRATION RAILS.



DETAIL "A"

MODEL NO.	APPROX. SHIPPING WEIGHT (LBS)	APPROX. OPERATING WEIGHT (LBS)	A	H
VTLO45-H	1650	2710	4'-0 3/4"	5'-1 1/4"
VTLO51-G	1750	2810	5'-7"	6'-6 1/4"
VTLO59-H	1770	2830	5'-7"	6'-6 1/4"
VTLO66-J	1840	2900	5'-7"	6'-6 1/4"
VTLO72-K	1870	2930	5'-7"	6'-6 1/4"
VTLO79-K	2040	3100	7'-1 5/16"	8'-1 13/16"

SEE DETAIL "A"

SEE DETAIL "A"

SEE DETAIL "A"

B.A.C. ORDER NO.	BALTIMORE AIRCOIL	COOLING TOWER	
DATE		DWG NO. BAC-15001B	A